CAPM-15 High Temperature Pickup System

Description:

The CAPM-15 High Temperature Pickup System consists of a CAPM-15/AMP signal amplifier module and the CP-30 high temperature carrier frequency pickup.

The **CAPM-15/AMP** will work on a supply voltage between 10 Volt DC and 30 Volt DC. The module is protected against reversed polarity on the voltage supply.

The length of wire between the CP-30 and the CAPM-15/AMP module should not be extended over 20

feet. The **CP-30** is supplied with a 7 foot cable only.

Technical Data:

Supply Voltage: 10 to 30 Volt DC


Supply Current: 9 mA @ 15 Volt, max 18mA

Signal Output: Square wave, Supply minus 2-3 V, peak-to-peak

Frequency Output: Flow dependent, up to 2000 Hz

Temperature range: CAPM-15/AMP: Up to 160°F/70°C

CP-30...... Up to 400°F/205°C



Connections:

1 - +10 to 30 Volt DC supply voltage


2 - Ground for supply and signals

3 - Not used

- 4 Signal from pickup & shield wire
- 5 Signal from pickup
- 6 Not used
- 7 Frequency signal output
- 8 Not used

Wire Color Code:

Supply Voltage: Red Ground: Black Signal: White



OUTPUT: 13V. peak-peak (4.2VRMS) @ 15V SUPPLY

Note: If signal does not go to ground, connect external resistor, 5 K-10 Kohm, between input and ground of monitoring equipment.

AW Flow Meters 8809 Industrial Drive, Franksville, WI 53126 **⑤** web: www.awflowmeters.com **☎** Tel: 262-884-9800 **ଛ** Fax: 262-884-9810 **☞** Email: awinfo@aw-lake.com
REV. 06/02 CAPM15.DOC

CAPM-15 SYSTEM

GREEN SHIELD WIRE CAN BE CONNECTED TO TERMINAL 4 WITH THE BLACK WIRE, OR DIRECTLY TO AN EARTH GOUND

GREEN(Shield) -(Connect to 4 or earth gnd) BLACK -7 FEET-(Connect to 4) WHITE (Connect to 5) CP-30-HIGH TEMP. PICKUP

SUPPLY VOLTAGE: 10-30 VDC


SUPPLY CURRENT: $\sim 9\,\text{mA}$ @ 15V, MAX 18mA


SIGNAL HIGH: ~13V PEAK @ 15V SUPPLY

SIGNAL LOW: ~OV DUTY CYCLE: ~50%

MINIMUM FREQUENCY: 0.5 Hz

LOAD: >3 Kohm





THE PRINT, INCLUDING THE INFORMATION CONTAINED IN IT. IS THE PROPERTY OF AN COMPANY. IT IS CONSIDERED PROPREHEASY IN NATURE AND MAY NOT BE USED OF DISCUSSED DUTSING DE AN COMPANY, EXCEPT UNDER PRIOR WRITTEN ARRESHENT. ANY MODERNATION MADE TO OR COMMENTS WRITTEN ON THIS DRAWING BY UNAUTHORIZED



TITLE: CAPM — 15	SYSTEM	

	THAT REMEM		
IATE 03-01-02	έ×	DRAVN BY	SHANE WILSON
CHEDKED BY: C.H.	FADE 1	or 1	204TE: NONE